

ADDENDUM #1

TO

SPECIFICATION AND CONTRACT DOCUMENTS

June 15, 2016

TO: ALL PLAN HOLDERS

FOR: ITB-020-2016
18" Water Pipe & Fittings – State Road 100

The purpose of addendum #1 is to answer questions received to date.

Contractor must acknowledge receipt of all addenda with bid proposal on the form provided herein.

- 1) MJ fittings and restraints - Tyler Union is the only fitting company on your list that still exist. May we quote Star and/or Sigma Co? **Yes**
- 2) Pipe - NAPCO and National. Will these be the only 2 allowed? Or can we quote Diamond for a third option? **No Diamond pipe.**
- 3) Tap Sleeves - Romac is listed. Will JCM be allowed? **Yes.**
- 4) Are Mueller, American and M&H the only Valves allowed? **Yes.** American Made valves only, no imports from China, India, etc? **No imports allowed.**
- 5) Is the "side shaft mount" on the valve actually a Bevel and Gear box for easier opening and closing? **The head of the valve is on the side for better clearance.**

No. 1 Dated _____

Signature: _____

THIS FORM MUST BE INCLUDED WITH BID PROPOSAL