

**ADDENDUM #1  
TO  
SPECIFICATION AND CONTRACT DOCUMENTS**

**May 16, 2017**

TO: ALL PLAN HOLDERS

FOR: FQ-010-2017  
Teen Town Renovation

This addendum sets forth changes and/or additional information as referenced and is hereby made a part of and should be attached to the subject Specifications and Contract Documents.

**Contractor must acknowledge receipt of all addenda with proposal on the form provided herein.**

**The purpose of addenda # is to provide answers to submitted questions.**

1. There are 2 exhaust fans (1 in each bathroom) these are not one the scope of work but will need to be moved down to new acoustical ceiling height.

**Answer: Yes, they do need to be moved. Add the removal and reinstallation of the exhaust fans to the Bathroom Renovations scope of work.**

2. The tile that was originally used in foyer area of building and purchased thru Brown Vann is now discontinued and no longer available. Would you like for us to use a similar color?

**Answer: Yes, something very similar will be acceptable.**

Addendum No. 1      Dated \_\_\_\_\_

Signature: \_\_\_\_\_

FAILURE TO SUBMIT ACKNOWLEDGEMENT OF ANY ADDENDUM THAT AFFECTS THE QUOTED PRICE IS CONSIDERED A MAJOR IRREGULARITY AND WILL BE CAUSE FOR REJECTION OF THE QUOTE.

**THIS FORM MUST BE INCLUDED WITH QUOTE**