

**ADDENDUM #1
TO
SPECIFICATION AND CONTRACT DOCUMENTS**

May 16, 2017

TO: ALL PLAN HOLDERS

FOR: FQ-010-2017
Teen Town Renovation

This addendum sets forth changes and/or additional information as referenced and is hereby made a part of and should be attached to the subject Specifications and Contract Documents.

Contractor must acknowledge receipt of all addenda with proposal on the form provided herein.

The purpose of addenda # is to provide answers to submitted questions.

1. There are 2 exhaust fans (1 in each bathroom) these are not one the scope of work but will need to be moved down to new acoustical ceiling height.

Answer: Yes, they do need to be moved. Add the removal and reinstallation of the exhaust fans to the Bathroom Renovations scope of work.

2. The tile that was originally used in foyer area of building and purchased thru Brown Vann is now discontinued and no longer available. Would you like for us to use a similar color?

Answer: Yes, something very similar will be acceptable.

Addendum No. 1 Dated _____

Signature: _____

FAILURE TO SUBMIT ACKNOWLEDGEMENT OF ANY ADDENDUM THAT AFFECTS THE QUOTED PRICE IS CONSIDERED A MAJOR IRREGULARITY AND WILL BE CAUSE FOR REJECTION OF THE QUOTE.

THIS FORM MUST BE INCLUDED WITH QUOTE