

**ADDENDUM #2  
TO  
SPECIFICATION AND CONTRACT DOCUMENTS**

**October 7, 2011**

TO: ALL PLAN HOLDERS

FOR: ITB-004-2012  
Metal Building

This addendum sets forth changes and/or additional information as referenced and is hereby made a part of and should be attached to the subject Specifications and Contract Documents.

**Contractor must acknowledge receipt of all addenda with proposal on the form provided herein.**

**The purpose of addenda # 2 is to provide answers to submitted questions.**

Does the interior space have to be completely clear? In other words can we have columns in the middle of the building?

**Answer: The interior space needs to be cleared with no columns in the middle of the building.**

Do the sides of the building need to be completely open as well? If we were to raise the eave height and add a small skirt wall dropping down only a few feet is this ok?

**Answer: The sides do not need to be completely open. Raising the eave height and adding a skirt wall is acceptable.**

In addendum 1 the question was asked about tapered or straight columns. You answered straight. This is not standard and will almost increase the cost of the building by 40%. Is there any reason for using straight columns that we need to be aware of.

**Answer: Tapered columns are acceptable.**

Addendum No. 1 Dated\_\_\_\_\_

Signature:\_\_\_\_\_

Addendum No. 2 Dated\_\_\_\_\_

Signature:\_\_\_\_\_

FAILURE TO SUBMIT ACKNOWLEDGEMENT OF ANY ADDENDUM THAT AFFECTS THE BID PRICES IS CONSIDERED A MAJOR IRREGULARITY AND WILL BE CAUSE FOR REJECTION OF THE BID.

**THIS FORM MUST BE INCLUDED WITH BID PROPOSAL**