

**ADDENDUM #1**  
**TO**  
**SPECIFICATION AND CONTRACT DOCUMENTS**

**December 18, 2014**

TO: ALL PLAN HOLDERS  
FOR: ITB-007-2015  
Pipe, Pipe Fittings & Materials – Westside Force Main Reroute

This addendum sets forth changes and/or additional information as referenced and is hereby made a part of and should be attached to the subject Specifications and Contract Documents.

**Contractor must acknowledge receipt of all addenda with bid proposal on the form provided herein.**

The purpose of addenda #1 is to answer written questions received to date.

Question 1: Under Section B, Items 1 and 2 are the same item. Is item 1 supposed to be a 45° bend and item 2 a 22.5° bend?

**Answer: Items B1 and B2 have been corrected. Please replace original page 6 of 19 with the attached revised “page 6 of 19”**

Question 2: Are Star pipe fittings and restraints allowed on this job?

**Answer: The City of Lake City Utility Department is not, at this time, in a position to evaluate utility material standards alternates. Please submit bids in accordance with existing standards.**

No. 1 Dated \_\_\_\_\_

Signature: \_\_\_\_\_

**THIS FORM MUST BE INCLUDED WITH BID PROPOSAL**

\*NOTE: ALL FITTINGS TO BE DUCTILE IRON AND MJ X MJ. PLEASE SEE ATTACHMENT FOR UTILITY STANDARDS.

"SPECIFICATIONS"

ITEM I: PIPE, PIPE FITTINGS AND MATERIALS

A. PIPE:

1. 12 INCH PVC DR 25 FORCE MAIN PIPE, GREEN IN COLOR.

a. Quantity – two thousand two hundred linear feet (2200 lf).

\$ \_\_\_\_\_ per ft.      \$ \_\_\_\_\_ total

B. PIPE FITTINGS:

1. EPOXY LINED DUCTILE IRON, **22.5°**, 12" FITTINGS LINED WITH PROTECTO 401 OR TNEMEC SERIES 431 PERMA-SHIELD PL (OR EQUAL) CERAMIC EPOXY.

a. Quantity – two (2)

\$ \_\_\_\_\_ each      \$ \_\_\_\_\_ total

2. EPOXY LINED DUCTILE IRON, **45°**, 12" FITTINGS WITH LINED WITH PROTECTO 401 OR TNEMEC SERIES 431 PERMA-SHIELD PL (OR EQUAL) CERAMIC EPOXY.

a. Quantity – two (2)

\$ \_\_\_\_\_ each      \$ \_\_\_\_\_ total

3. EXPOXY LINED DUCTILE IRON, WYE, 12" FITTING LINED WITH PROTECTO 401 OR TNEMEC SERIES 431 PERMA-SHIELD PL (OR EQUAL) CERAMIC EPOXY.

a. Quantity – one (1).

\$ \_\_\_\_\_ each      \$ \_\_\_\_\_ total