

**ADDENDUM #1
TO
SPECIFICATION AND CONTRACT DOCUMENTS**

December 19, 2013

TO: ALL PLAN HOLDERS

FOR: ITB-008-2014
Pipe, Pipe Fittings, & Fire Hydrants

This addendum sets forth changes and/or additional information as referenced and is hereby made a part of and should be attached to the subject Specifications and Contract Documents.

Contractor must acknowledge receipt of all addenda with proposal on the form provided herein.

The purpose of addenda # 1 is to answer written questions received to date.

Question 1: The 12" MJ tee and the 12"x2" MJ tapped plug are listed as C110 while the other fittings are listed as C153. Are these 2 items in fact supposed to be C110?

Answer: all fittings are C153 class

Addendum No. 1 Dated_____

Signature:_____

THIS FORM MUST BE INCLUDED WITH BID PROPOSAL