

**ADDENDUM #1
TO
SPECIFICATION AND CONTRACT DOCUMENTS**

February 3, 2012

TO: ALL PLAN HOLDERS

FOR: ITB-009-2012
Construction of a Restroom Facility at Wilson Park

This addendum sets forth changes and/or additional information as referenced and is hereby made a part of and should be attached to the subject Specifications and Contract Documents.

Contractor must acknowledge receipt of all addenda with proposal on the form provided herein.

The purpose of addenda # 1 is to provide answers to submitted questions.

1. Is the contractor required to provide a site plan and Suwannee River Water Management District Permitting, or is the city doing this?
Contractor responsibility.
2. Where on the site is the restroom to be located and what sewer and water connections are available.
Sewer and water is located on the north side of the restroom location.
3. How do we bid this without knowing the distance from the bathroom to the connection point?
Site visit.
4. The plumbing notes indicate using Type L copper, or schedule 40 CPVC at the owner's option. Which option should we bid?
CPVC
5. The plumbing notes indicate using cast iron drain pipes, or schedule 40 PVC at the owner's option. Which option should we bid?
PVC
6. The specifications indicate options for roofing. What are the options?
Item 3 on page 8 "Specifications" states the roof is to be metal.

7. The plans show a hip roof but the specs call for a gable roof. Do we go by the specs?
The plans show both a hip roof and a gable roof. The specifications indicate the gable roof.

8. Is the city going to use their tax exempt status to direct purchase all materials, thus eliminating the 7% sales tax for all material, or is the contractor required to purchase all the material and incur the 7% sales tax, which then get passed on to the city?
The City will not be making direct purchases for any materials.

Addendum No. 1 Dated _____

Signature: _____

FAILURE TO SUBMIT ACKNOWLEDGEMENT OF ANY ADDENDUM THAT AFFECTS THE BID PRICES IS CONSIDERED A MAJOR IRREGULARITY AND WILL BE CAUSE FOR REJECTION OF THE BID.

THIS FORM MUST BE INCLUDED WITH BID PROPOSAL