



NOTES:

1. ALL 2" PIPE AND FITTINGS SHALL BE SCHEDULE 40 GALVANIZED STEEL OR BRASS WITH THREADED (NPT) JOINTS.
2. BEND SHALL BE ROTATED APPROXIMATELY 20° FROM VERTICAL.

Date	Revisions	Appr. by

CITY OF LAKE CITY			
BLOW OFF VALVE DETAIL			
Date: Sept. 1996	Scale: N.T.S.	Dwg: Q403	Fig: 403