

**ADDENDUM #1  
TO  
SPECIFICATION AND CONTRACT DOCUMENTS**

**April 16, 2013**

TO: ALL PLAN HOLDERS

FOR: ITB-013-2013  
Construction of Four Racquetball Courts

This addendum sets forth changes and/or additional information as referenced and is hereby made a part of and should be attached to the subject Specifications and Contract Documents.

**Contractor must acknowledge receipt of all addenda with proposal on the form provided herein.**

**The purpose of addenda # 1 is to answer questions received. Duplicate questions will only be answered once.**

1. In the site work specifications, A:1 states the City shall provide final floor elevation grade for the project. Does this mean the City will give us the exact elevation grade or will the sub grade on grade? **Sub grade.**
2. What is the general lay out of the four courts? All four in a row or two side by side with two behind? **All four in a row.**
3. If courts are to be side by side, can the courts share walls? **Yes.**
4. Is there any pre-qualification process required for this project? **No.**
5. Are there any plans and specifications available for this project other than the specifications outlined in the ITB document? **No.**
6. Is there an estimated budget for this project? **No.**
7. What provisions are there for draining the water off the courts as there are no floor drains or weep holes listed? **The floor will be sloped to provide for drainage. Please see page 4; Site Work; Section A.2.**

Addendum No. 1      Dated \_\_\_\_\_

Signature: \_\_\_\_\_

**THIS FORM MUST BE INCLUDED WITH BID PROPOSAL**