

**ADDENDUM #3  
TO  
SPECIFICATION AND CONTRACT DOCUMENTS**

**June 28, 2013**

TO: ALL PLAN HOLDERS

FOR: ITB-017-2013  
Wilson Park Event Pavilion

This addendum sets forth changes and/or additional information as referenced and is hereby made a part of and should be attached to the subject Specifications and Contract Documents.

**Contractor must acknowledge receipt of all addenda with proposal on the form provided herein.**

The purpose of addenda #3 is to answer additional written questions received to date.

1. If the door sizes are 3'0" x 6'8" OR 3'0" x 7'0", you will only require 3 hinges per door opening. Per the Florida Building Codes, you must furnish materials that have been tested. All hollow metal manufactures have tested these sizes with 3 hinges only. Advise if 3 hinges will be acceptable and what actual door size will be required.  
**3 hinges will be acceptable; requiring 4 would be additional cost as special order. 3'0"x 6'8" will be sufficient for the restrooms. A 3'0"x 7'0" for the kitchen area will be required.**
2. Advise how the metal frame is to be fastened/anchored?  
**Frame will be anchored with counter sunk stainless grade wood screw or bolt. You must specify manufacturer's POA for the frame type for proper installation in frame walls.**
3. Please advise the hardware requirements.  
**Stainless hardware will be used.**
4. Do we need to furnish stainless steel hinges?  
**Stainless hardware will be used on doors.**
5. Grade 2 locksets would require the use of a deadbolt. Grade 1 locksets have passed exterior use without a dead bolt. We recommend using a dead bolt at this type of project.  
**Use grade 2 lockset with deadbolt for kitchen area; grade 1 may be used on restroom without dead bolts; use Russwin or equivalent quality locks.**

6. Do all three openings require a door closer? Recommended for exterior openings.  
**Public type restrooms require door closure devices; kitchen area does not.**
7. Are we to furnish threshold and weather strip at each opening?  
**Yes. Threshold for doors shall be no higher than 1/2 inch.**

Addendum No. 1      Dated\_\_\_\_\_

Signature:\_\_\_\_\_

Addendum No. 2      Dated\_\_\_\_\_

Signature:\_\_\_\_\_

Addendum No. 3      Dated\_\_\_\_\_

Signature:\_\_\_\_\_

**THIS FORM MUST BE INCLUDED WITH BID PROPOSAL**