

**ADDENDUM #1  
TO  
SPECIFICATION AND CONTRACT DOCUMENTS**

**June 6, 2014**

TO: ALL PLAN HOLDERS

FOR: ITB-025-2014  
35' x 62' Metal Pole Barn – Bio Solids Site

This addendum sets forth changes and/or additional information as referenced and is hereby made a part of and should be attached to the subject Specifications and Contract Documents.

**Contractor must acknowledge receipt of all addenda with bid proposal on the form provided herein.**

The purpose of addenda #1 is to provide additional information and to answer questions received to date.

The deadline for receiving written questions is Tuesday, June 10, 2014 at 4 p.m. Questions may be sent via email to [burksl@lcfla.com](mailto:burksl@lcfla.com) or faxed to 386-755-6112.

Question 1. Are the roof panels galvalume or painted? **Galvalume**

Question 2. Can we use cross bracing in the walls? **Cross bracing limits access; use wind column**

Question 3. Is a bid bond required? **No.**

Question 4. The bid documents ask for 20' tall building and right below ask for 20' clearance --- if they are asking for 20' clear height inside the building, eave height needs to be around 24' – can you please clarify? **20 ft. clearance into and out of the structure is required.**

No. 1 Dated \_\_\_\_\_

Signature: \_\_\_\_\_

**THIS FORM MUST BE INCLUDED WITH BID PROPOSAL**